



Notes:

- 1- All grounding requirements for controllers shall conform to local electric codes.
- 2- Grounding rod shall not be located in the same trench as the irrigation mainlines or lateral lines.
- 3- Valve box shall be wrapped with a minimum 3 mil thick plastic and secured to the valve box using duct tape or electrical tape.
- 4- Install grounding rod per the controller manufacturer's specifications and recommendations.



GROUNDING ROD